SIEMENS

Product data sheet 3SB3601-1HR20



22MM METAL ROUND COMPLETE UNIT COMBINATION: EMERGEN.-STOP MUSHR.PUSHB. 40MM LATCH.W. ROT. -TO-UNLATCH MECH. WITH YELLOW BACKING PLATE SCREW TERMINAL, 1NO+1NC WITH HOLDER RED INSCRIPTION: EMERGENCY STOP

Enclosure:				
Material / of the enclosure		metal		
Form / of the enclosure front		round		
Actuato/ signaling device:				
Design of the product		Complete unit round with positive latching in accordance with ISO 13850		
Design of the operating mechanism		Emergency stop mushroom pushbutton		
Functionality / of the actuator		Latching		
Type of unlocking device		rotate-to-unlatch mechanism		
Color / of the activation element		Red		
Material / of the activation element		plastic		
Number of switching positions		2		
Product component / front ring		No		
Holder:				
Material / of the holder		Metal		
Contact block/ lampholder:				
Design of the electrical connection		screw-type terminals		
Number of switching elements		1		
Number of NC contacts / for auxiliary contacts		1		

Number of NO contacts / for auxiliary contacts	1
Number of changeover contacts / for auxiliary contacts	0
Product function / positive opening	Yes
Number of lampholders	0
Product component / fluorescent materials	No
Product extension / optional / fluorescent materials	No

Accessories:

Product component / holder for 3 switching elements No

General technical details:		
Voltage type / of operating voltage		AC/DC
Operating voltage		
• rated value	V	5 400
Operating current		
• at AC-12		
• at 24 V / rated value	Α	10
• at 48 V / rated value	Α	10
• at 110 V / rated value	Α	10
• at 230 V / rated value	Α	10
• at 400 V / rated value	Α	10
• at AC-15		
• at 24 V / rated value	Α	6
• at 48 V / rated value	Α	6
• at 110 V / rated value	Α	6
• at 230 V / rated value	Α	6
• at 400 V / rated value	Α	3
• at DC-12		
• at 24 V / rated value	Α	10
• at 48 V / rated value	Α	5
• at 110 V / rated value	Α	2.5
• at 230 V / rated value	Α	1
• at DC-13		
• at 24 V / rated value	Α	3
• at 48 V / rated value	Α	1.5
• at 110 V / rated value	А	0.7
• at 230 V / rated value	Α	0.3
• for devices without incandescent lamp / according to IEC 60068-2-27		<= 50g
Resistance against vibration / according to IEC 60068-2-6		20 200 Hz: 5g
Operating cycles / maximum	1/h	1,000

Mechanical operating cycles as operating time / typical		300,000
Reference code		
 according to DIN EN 61346-2 		S
 according to DIN 40719 extended according to IEC 204-2 / according to IEC 750 		S
Tightening torque / of the screws in the bracket / maximum	N⋅m	1
during operating	°C	-25 +70
during storage	°C	-40 +80
Protection class IP		IP67
B10 value / with high demand rate / according to SN 31920		100,000
Proportion of dangerous failures / with high demand rate / according to SN 31920	%	20
Proportion of dangerous failures / with low demand rate / according to SN 31920	%	20
Failure rate [FIT] / with low demand rate / according to SN 31920	FIT	100
T1 value / for proof test interval or service life / according to IEC 61508	а	20
climatic class / during the operating phase / according to EN 60721		3K6
Mounting type		front mounting
Shape / of the installation hole		round
Installation width	mm	40.5
Mounting diameter	mm	22
Mounting height	mm	49
Mounting depth	mm	63

Certificates/ approvals:

General Product Approval

Declaration of Conformity

Test Certificates









Special Test Certificate

Shipping Approval











other

Confirmation

other

Environmental Confirmations

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

 $\underline{\text{http://www.siemens.com/industrial-controls/catalogs}}$

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator


http://www.siemens.com/cax

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3SB3601-1HR20/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

 $\underline{\text{http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3SB3601-1HR20}$



last change: Jun 9, 2014